


1 HVAC FIRST FLOOR
SCALE: 1/8"=1'-0"

- KEYED NOTES
- EXISTING 2 PSI NATURAL GAS METER.
 - EXISTING EXHAUST FANS.
 - EXISTING INLET / OUTLET; REBALANCE FOR AIR FLOW INDICATED.
 - WALL MOUNT ELECTRIC HEATER (BY ELECTRICIAN).
 - RETURN OPENING ON TOP OF DUCT. COVER OPENING WITH 1/4" MESH GALV. STEEL SCREEN.
 - APPROX. LOCATION FOR (E) THERMOSTAT. VERIFY LOCATION, FUNCTION, AND SETUP.

REV	BY	REVISION	DATE
A	CMP	PLAN REVIEW	01NOV17
B	RGM	STRUCT., ARCH., & VE REVISIONS	19JAN18



COMFORT FLOW HEATING
AND AIR CONDITIONING
1951 Dot Street | Springfield, OR 97477
OFFICE: (541) 726-0100 | FAX: (541) 725-4799
www.comfortflow.com
Engineering, Design, Budgeting, Installation & Service

ALL RIGHTS RESERVED.
NO PART OF THIS DOCUMENT
MAY BE USED, REPRODUCED OR
TRANSMITTED IN ANY FORM OR BY
ANY MEANS, ELECTRONIC OR
MECHANICAL, WITHOUT WRITTEN
PERMISSION FROM
THE ENGINEERING DEPARTMENT OF
COMFORT FLOW HEATING.

SUMMIT CREEK CHURCH

275 WEST 5th AVE.
EUGENE, OREGON

PROJECT TYPE:
HVAC FIRST FLOOR

DRAWN BY:
RGM DRAFTING

DESIGNED BY: JE / CMP	CHECKED BY: CMP
FILE NAME: SCC-M	PROJECT NO.:
DRAWING SCALE: AS NOTED	DATE: 09OCT17
PLOT SCALE: 1-1	REV: B
SHEET: 5 OF 7	SHEET NO.: